

SEKID Microbial Testing

SITE LOCATION & DATE	TURBIDITY NTU	FREE CL MG/L	Total Coliform CFU/100 mL	E. Coli CFU/100 mL
INTAKE				
December 5, 2011	1.20		50	<1
December 12, 2011	1.24		120	<1
December 19, 2011	1.44		60	<1
December 23, 2011	1.54		>34	<1
RECORDER BLDG				
December 5, 2011		2.50	<1	<1
December 12, 2011		2.17	<1	<1
December 19, 2011		3.20	<1	<1
December 23, 2011		2.00	<1	<1
FIELD RD RESERVOIR				
December 5, 2011		1.66	<1	<1
December 12, 2011		2.02	<1	<1
December 19, 2011		2.20	<1	<1
December 23, 2011		2.20	<1	<1
DUNSTER RD				
December 5, 2011		1.16	<1	<1
December 12, 2011		0.99	<1	<1
December 19, 2011		1.09	<1	<1
December 23, 2011		0.71	<1	<1
HART @ GULLEY RD				
December 5, 2011		0.44	<1	<1
December 12, 2011		0.06	<1	<1
December 19, 2011		0.40	<1	<1
December 23, 2011		0.51	<1	<1
TODD & SAUCIER				
December 5, 2011		1.32	<1	<1
December 12, 2011		1.51	<1	<1
December 19, 2011		1.90	<1	<1
December 23, 2011		1.54	<1	<1
STEWART RD WEST				
December 5, 2011		0.54	<1	<1
December 12, 2011		0.54	<1	<1
December 19, 2011		0.91	<1	<1
December 23, 2011		0.71	<1	<1
JOHNSON RD (WELL)				
December 5, 2011		1.21	<1	<1
December 12, 2011		n/a	<1	<1
December 19, 2011		n/a	<1	<1
December 23, 2011		n/a	<1	<1
GASPARDONE RD				
December 5, 2011		0.54	<1	<1
December 12, 2011		1.87	<1	<1
December 19, 2011		1.03	<1	<1
December 23, 2011		0.89	<1	<1