

<b>SITE LOCATION &amp; DATE</b>	<b>TURBIDITY NTU</b>	<b>FREE CL MG/L</b>	<b>Total Coliform CFU/100 mL</b>	<b>E. Coli CFU/100 mL</b>
<b>2014</b>				
<b>INTAKE</b>				
January 4, 2016	1.25	4.99	0	0
January 11, 2016	1.46	5.22	0	0
January 18, 2016	1.51	5.35	0	0
January 25, 2016	1.57	5.22	0	0
<b>RECORDER BUILDING</b>				
January 4, 2016		2.03	0	0
January 11, 2016		2.08	0	0
January 18, 2016		1.73	0	0
January 25, 2016		1.98		
<b>FIELD RD RESERVOIR</b>				
January 4, 2016		1.73	0	0
January 11, 2016		1.92	0	0
January 18, 2016		1.59	0	0
January 25, 2016		1.70	0	0
<b>DUNSTER RD</b>				
January 4, 2016		1.02	0	0
January 11, 2016		1.08	0	0
January 18, 2016		1.09	0	0
January 25, 2016		1.06	0	0
<b>HART @ GULLEY RD</b>				
January 4, 2016		0.12	0	0
January 11, 2016		0.13	0	0
January 18, 2016		0.44	0	0
January 25, 2016		0.25	0	0
<b>TODD &amp; SAUCIER</b>				
January 4, 2016		1.41	0	0
January 11, 2016		1.87	0	0
January 18, 2016		1.28	0	0
January 25, 2016		1.43	0	0
<b>STEWART RD WEST</b>				
January 4, 2016		0.65	0	0
January 11, 2016		0.38	0	0
January 18, 2016		0.68	0	0
January 25, 2016		0.52	0	0
<b>JOHNSON RD (WELL)</b>				
January 4, 2016		n/a	0	0
January 11, 2016		n/a	0	0
January 18, 2016		n/a	0	0
January 25, 2016		n/a	0	0
<b>GASPARDONE RD</b>				
January 4, 2016		0.33	0	0
January 11, 2016		0.54	0	0
January 18, 2016		0.65	0	0
January 25, 2016		0.53	0	0