

May 2010 Microbial Test Results

SITE LOCATION & DATE	TURBIDITY NTU	FREE CL MG/L	Total Coliform CFU/100 mL	E. Coli CFU/100 mL
INTAKE				
May 3, 2010	2.69		30	1
May 10, 2010	1.59		15	6
May 17, 2010	2.76		99	4
May 25, 2010	2.60		22	5
May 31, 2010	1.60		49	4
RECORDER BLDG				
May 3, 2010		1.64	<1	<1
May 10, 2010		2.40	<1	<1
May 17, 2010		2.70	<1	<1
May 25, 2010		3.10	<1	<1
May 31, 2010		1.88	<1	<1
FIELD RD RESERVOIR				
May 3, 2010		1.84	<1	<1
May 10, 2010		0.91	<1	<1
May 17, 2010		2.20	<1	<1
May 25, 2010		3.70	<1	<1
May 31, 2010		1.86	<1	<1
DUNSTER RD				
May 3, 2010		0.18	<1	<1
May 10, 2010		0.78	<1	<1
May 17, 2010		0.06	<1	<1
May 25, 2010		1.82	<1	<1
May 31, 2010		0.20	<1	<1
HART @ GULLEY RD				
May 3, 2010		0.58	<1	<1
May 10, 2010		0.98	<1	<1
May 17, 2010		0.79	<1	<1
May 25, 2010		1.75	<1	<1
May 31, 2010		0.58	<1	<1
TODD & SAUCIER				
May 3, 2010		0.70	<1	<1
May 10, 2010		1.01	<1	<1
May 17, 2010		1.27	<1	<1
May 25, 2010		1.76	<1	<1
May 31, 2010		0.68	<1	<1
STEWART RD WEST				
May 3, 2010		0.13	<1	<1
May 10, 2010		1.03	<1	<1
May 17, 2010		1.05	<1	<1
May 25, 2010		1.60	<1	<1
May 31, 2010		0.73	<1	<1
JOHNSON RD (WELL)				
May 3, 2010		n/a	<1	<1
May 10, 2010		n/a	<1	<1
May 17, 2010		n/a	<1	<1
May 25, 2010		n/a	<1	<1
May 31, 2010		n/a	<1	<1
GASPARDONE RD				
May 3, 2010		0.86	<1	<1
May 10, 2010		1.13	<1	<1
May 17, 2010		1.38	<1	<1
May 25, 2010		1.17	<1	<1
May 31, 2010		1.12	<1	<1